
GENERAL NOTES:

- 1. "H" is measured from top of bottom slab to the normal autter grade line undepressed at the curb face.
- 2. For "T" wall thickness and reinforcement, see Table C on Standard Plan D72G.
- Wall reinforcement must be placed in the center of the wall thickness with horizontal 3, bars placed on the exterior face. Bottom slab concrete cover must be 3" clear on the interior face unless otherwise noted. Top slab concrete cover must be 2" clear on the exterior face unless otherwise noted. Reinforcement spacing is in inches unless otherwise noted.
- Steps None required where "H" is less than 2'-6". Where "H" is 2'-6" or more, install steps - None required where H is less final 2-6, where H is 2-6 or more, install 4. steps with lowest rung 1'-0" above the floor and highest rung not more than 6" below bottom of lid. The distance between steps must not exceed 1'-0" and be uniform throughout the length of the wall. Place steps in the wall without an opening. Steps inserts may be substituted for the bar steps. Step inserts must comply with State Industrial Safety Requirements, See Standard Plan D74 for step details.
- Pipe(s) can be placed in any wall. Adjacent to each side of the opening, place additional 5. reinforcement equivalent to half the interupted main reinforcement. For larger pipes greater than or equal to 42" diameter, also add 4 diagonal bars, 1 bar each side. Bars must be the same size as the larger of the main vertical or horizontal bars. Extend bars one development length past the intersection with the adjacent diagonal bar, or where bars intersect mid thickness of adjacent wall bottom or top of non-continuous wall, bend ends as required into same plane.
- Set inlet so that grate bars are parallel to direction of principal surface flow.
- Curb section must match adjacent curb.
- Except for inlets used as junction boxes, basin floors must have wood trowel finish and 8. a minimum slope of 4:1, unless otherwise noted, from all directions toward outlet pipe by casting grout fill on top of the bottom slab. The additional volume to achieve the 4:1 slope may also be achieved by casting the bottom slab and fill as a composite concrete element.
- See Standard Plans D77A and D77B for grate and frame details and weights of 9. miscellaneous iron and steel.
- See Standard Plans D78A and D78B for gutter depression details.
- See Standard PlanS A87A and A87B for curb and dike details.
- 11.
- Details shown apply to metal, concrete and plastic pipe(s). 12.
- The Contractor may use WWR instead of bar reinforcement. The ratio of bar 13. reinforcement to WWR shall be based on the yield strength ratio.
- Cast-in-place (CIP) inlets to be formed around all pipes/stubs intersecting the inlet, 14, and concrete poured in one continuous operation.
- Perimeter reinforcement must not be smaller than main bars and #4 and serves as a 15. rigid frame to position and attach the required structural reinforcement and may be tack welded at outer corners when using ASTM A706 weldable bars.

DESIGN NOTES:

- Design Specifications: AASHTO LRFD Bridge Design Specifications, 6th edition with 2012 Interims and Errata and CA Amendments.
- 2. Live Load (AASHTO LRFD 3.6.1.2): HL-93, consists of design fruck or tandem, and design lane load.
 Dynamic Load Allowance, IM = 33%
 Multiple Load Rector, m = 1.0 Design lane load was excluded in Top Slab design. A wheel load of 8 kips without impact factor was used for top slabs that are above a curb.
- Vertical pressure = 140 pcf
- Lateral pressure:
 = 100 pcf for walls with flat embankment
 = 140 pcf For walls with slope embankment, 1.5:1 Max
- 4. Downdrag: $\emptyset = 34^{\circ}$ and $\gamma_{\rm F} = 120$ pcf.
- 5. Buoyancy: $\gamma_{\rm W}$ = 62.4 pcf to finished grade
- 6. Reinforced Concrete: f'c = 3.6 ksi, fy = 60.0 ksi.
- 7. Soil pressures shown are factored per AASHTO LRFD and include self-weight, live load and downdrag.




TYPICAL INLET PLAN

* ALTERNATIVE HORIZONTAL BARS







W/ PIPE OPENING

* SEE "SKEWED PIPE PLAN"

Min *PIPE PENETRATION DIAMETER * VARIES

SKEWED PIPE PLAN

* ADJUST PIPE PENETRATION AND BOX WIDTH FOR SKEWED PIPES.

STATE OF CALIFORNIA DEPARTMENT OF TRANSPORTATION

CIP DRAINAGE INLET NOTES

NO SCALE

D72F

2018

ဟ

TAND

ARD

PL

Ž

0 72